

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 2560-1055:101

Page 1 of 1

CATEGORY: Plastics

LISTEE: King & Co., PO Box 10, Clarksville, AR 72830
Contact: BJ Stone *(479) 754-6090 Fax (479) 754-8445

DESIGN: Models THERMO-TILE 2200, 5827, 2201, and 4124 plastic ceiling tile; polystyrene, 1.75 lbs./cu. Ft. density for suspended tee bar non-rated ceilings. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	ITEM	FLAMESPREAD	SMOKE DENSITY
	5/8"	5	42-128
	1"	10	264-407

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and FM label.

APPROVAL: Listed as plastic ceiling finish material for suspended, non-rated ceilings where permitted by code. Also suitable for use with automatic fire sprinklers except where prohibited by code.

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**